



This is to Certify

GENT BY HONEYWELL

Hamilton Industrial Park, 140 Waterside Road, Leicester, LE5 1TN, United Kingdom

is authorised to use the LPCB mark in association with the product listed in this certificate and appendix.

**S4-34740 Analogue addressable optical beam smoke detector
with short circuit isolator**

which has complied with the requirements of the following:

EN 54-12:2002 and EN 54-17:2005

Certificate No: 042bh

Issue Number: 01

Date of Issue: 9 June 2011

Signed for and on behalf of LPCB

EMAN MATTIE-SULEIMAN

breglobal

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.



Appendix to Certificate

Certificate No: 042bh

GENT BY HONEYWELL

Certified Products

LPCB Ref. No.

S4-34740 Analogue addressable optical beam smoke detector with short circuit isolator (S4-34741-01 and S4-34741-03).
Notes:
1) The S4-34740 beam sensor pair comprises of an S4-34741 beam transmitter, plus an S4-34742 beam receiver.
2) Meets the requirements of EN 54-12 at the following sensitivity settings:
States 0, 1: 3.01dB
States 2, 3: 1.25dB

042bh/01

Ancillaries:

S4-34741-01, beam angle bracket
S4-34741-03, beam parallel bracket

Appendix Issue No: 01

Page: 2 of 2

Date of Issue: 9 June 2011

Signed for and on behalf of LPCB

EMAN MATTIE-SULEIMAN



breglobal

LPCB is part of BRE Global Limited, Watford, WD25 9XX T: +44 (0)1923 664100 F: +44 (0)1923 664910 W: www.redbooklive.com
This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions. It is maintained and held in force through annual review and verification. To check the authenticity of this certificate, please visit www.redbooklive.com or contact us.